

COMPARITIVE STATEMENT FOR PURCHASE OF 5-6 KVA / 4KW UPS

TENDER OPENED ON  
28.01.2019

SPECIFICATION OF UPS	QTY	Rana Traders			ESAC			Panasonic Office Product			Quick Business Solution		
		Tech: Avel:	Quted Rates	Total	Tech : Avel:	Quted Rates	Total	Tech: Avel:	Quted Rates	Total	Tech: Avel:	Quted Rates	Total
<b>5-6 KVA / 4KW</b> Pure Sine Wave output  48 Volt DC 60 Ampere Heavy Charger Solar Support 50 60 Hz Auto Sense <u>GEL BATTERY WITH BATTERY BANK (200AHX4)</u> Non Spill able Deep Cycle GEL Electrolyte  Higher Capicity Stable Characteristicts in higher temperature of 45 degrees or higher Long life cycle as compared to ordinary lead acid battery LCD on top of battery for viewing volt, battery life, battery status etc <u>INSTALLATION OF UPS * BATTERY AND BATTERY BANK</u> Installatiion of UPS and battery connectivity with selected area along with complete electRICT wiring of user selected points and labour charges including with proposal and battery backup required approximated 2 to 3 hours	2	Y	370100	740200	Y	374985	749970	Y	367360	734720	Y	544447	1088894
				740200			749970			734720			1088894

The Panasonic Office Product Peshawar offer lowest rates in UPS 5-6KVA/4KW and fullfilling the required performance specification, therefore recumended for supply.

Assistant Director (AF)  
(CB&S) of Finance Department

REPRESENTATIVE  
OF ST&IT

Section Officer (Admin)  
Finance Department

Director FMTU  
Finance Department

Deputy Secretary (Bgt-I)  
Finance Department

PROJECT DIRECTOR  
CB&S OF FINANCE DEPTT